



QUADRUPLE SERVICE MANIFOLD

NOT TO SCALE

NOTES:

1. USE GATE VALVE SERVICE CONNECTION SEE DETAIL 701.
2. FOR 5/8" x 3/4" METER SETTERS, 2" MANIFOLD LENGTH BETWEEN SETTERS SHALL BE 30". FOR 1" METER SETTERS, 2" MANIFOLD LENGTH BETWEEN SETTERS SHALL BE 24".
3. FOR 5/8" x 3/4" METER SETTERS, MANIFOLD SIZE SHALL BE 3/4" FROM BUSHING AT TEE. FOR 1" METER SETTERS, MANIFOLD SIZE SHALL BE 1" FROM BUSHING AT TEE.
4. FOR 5/8" x 3/4" METER SETTERS, MANIFOLD LENGTH BETWEEN SETTERS SHALL BE 18". FOR 1" METER SETTERS, MANIFOLD LENGTH BETWEEN SETTERS SHALL BE 24".
5. FOR 5/8" x 3/4" METER SETTERS, USE 2-17"x30" METER BOXES AS SHOWN. FOR 1" METER SETTERS, USE INDIVIDUAL METER BOXES SIMILAR TO THE SINGLE SERVICE DETAIL 703.
6. THE METER BOXES SHALL BE CENTERED OVER THE METER SETTER ASSEMBLIES AS SHOWN.

APPROVED: WILLIAM J. CAMPBELL

REV. DATE: JULY 01, 2007

WATER/WASTEWATER DIVISION



STANDARD DETAILS

QUADRUPLE SERVICE MANIFOLD

FILE SD703C.DGN DRAWING NO. 703C